

Hazardous Substance Test Certificate Stationary Container – Design (Class3 Flammables)

Issued pursuant to Section 82 of the
Hazardous Substances and New Organisms Act 1996

Issued to: All Purpose Engineering Limited

Certificate No: 000034-11931

Contact Details:

Nigel Lee
129 Crinan Street
Invercargill 9812
0211 932 800

Fabrication Plant address:

All Purpose Engineering Ltd
129 Crinan Street
Invercargill
03 218 8600

This certificate is issued in accordance with Schedule 8 Part 19, Clause 92 of the Hazardous Substances (Dangerous Goods and Scheduled Toxic Substances) Transfer Notice 2004 (as amended). This certifies that the relevant requirements have been met for the substances and stationary container design specified below at the maximum capacity identified.

Type	Above ground stationary tanks with integral secondary containment
Manufacturer	All Purpose Engineering Ltd
Design Spec	AS1692-2006 Cat 2 incorporating amendment No1
Dwg Ref No	KM Mechanical Ltd: Drwg No. 2247-01 & 2247 -02
Design Review	KM Mechanical Ltd: Kevin Mair MIPENZ CPEng, Reg No. 243859
Capacity	1,500 Litres
Material	3mm mild steel shell plate
Substances certified for storage	Flammable Liquids Class 3.1A Petrol & 3.1D Diesel

Conditions:

- This certificate becomes invalid if workshop quality assurance systems change.
- Welders to be qualified to ASNZS2980-2007
- Installation to comply with HSNO COP24 version 2 July 2014
- Manufacturers plate to be attached to each tank.
- Unless surrendered or revoked beforehand, this certificate shall remain in force until the expiry date stated below, at which time it may be renewed by an authorised Test Certifier.
- This certificate must be produced at the request of an Enforcement Officer appointed under the HSNO Act 1996.


Trevor McQuoid

Test Certifier Registration No: 000034

Date Issued: 18 August 2016

Expiry Date: 18 August 2019